

ESTD : 1987



PHONE : 08350-270235 (O)
Fax : 08350-271466
Website : klescpcdds.edu.in
E-mail : scpdgcol@gmail.com

ಕೆ. ಎಲ್. ಇ. ಸಂಸ್ಥೆಯ
ಶ್ರೀ ಚನ್ನಗಿರೀಶ್ವರ ಪ್ರಸಾದಿಕ ಕಲಾ, ವಿಜ್ಞಾನ ಹಾಗೂ ದಂ. ದಾ. ಶಿರೋಳ ವಾಣಿಜ್ಯ ಮಹಾವಿದ್ಯಾಲಯ,

ತಾ. ರಬಕವಿ-ಬನಹಟ್ಟಿ ಮಹಾಲಿಂಗಪುರ-೫೮೭ ೩೧೨. ಜಿ. ಬಾಗಲಕೋಟೆ
(ನ್ಯಾಕ ಮಾನ್ಯತೆ 'A' ಶ್ರೇಣಿ 3.10 CGPA)

K.L.E. SOCIETY'S

Shri Channagirishwar Prasadik Arts, Science & D. D. Shirol Commerce College,

Tq : Rabakavi-Banahatti

MAHALINGPUR-587 312.

Dist : Bagalkot

(NAAC Accredited 'A' Grade with 3.10 CGPA)

ಉಲ್ಲೇಖ ಸಂಖ್ಯೆ : ಡಿ.ಎ. / 65/2025-26

ದಿನಾಂಕ : 19/5/2025

To,
Chief Fire Officer,
Karnataka State Fire and
Emergency Services Zone,
Hubballi - 580025

Subject: Regarding renewal of Fire Safety Certificate

Ref No: C.NO/256/CC/DFO/BAGALKOT/2024 Dated: 28-03-2024

Respected Sir,

With reference to the subject cited above and as per your recommendation mentioned compliance certificate our staff has taken fire safety training under **Fire Prevention and Firefighting** from 22-08-2024 to 23-08-2024 for 2 days at office of the chief fire officer, Amargol fire station premises, Hubballi - 25, Hence requesting to renew Fire safety certificate.

This is for your kind information and further action.

Thanking You,

23/05/2025
OFFICE OF THE
CHIEF FIRE OFFICER
Karnataka State Fire and
Emergency Services,
HUBBALLI-25.

Yours Faithfully
PRINCIPAL
K.L.E. Society's S.C.P. Arts, Science
& D.D.S. Commerce College,
MAHALINGPUR-587312. Dist. Bagalkote

C.NO.271/CFO/HUBLI/CC Renewal/2025

DATE :17-06-2025

SUB : RENEWAL OF COMPLIANCE CERTIFICATE


- Ref: (1) C.No.256/CC/DFO/Bagalkot/2024 dated 28/03/2024
(2) Applicant request letter dated 19/05/2025
(3) C.No.417/DFO/Bagalkot/2025 dated 13/06/2025

This is to certify that, The Compliance was issued by the Fire and Emergency Services Department to "K.L.E. Society's Shri Channagirishwar Prasadik Arts, Science & D.D Shirol Commerce College, Sy.No.66, 67, 68, 69, Mahalingpur, Rabakavi-Banahatti Taluk, Bagalkot District" for the installation of fire fighting systems in the above said address vide ref (1).

Now the applicant in his letter vide ref (2) requested to this office to renew the compliance Certificate.

As per ref (3) the District Fire Officer, Bagalkot has inspected the K.L.E. Society's Shri Channagirishwar Prasadik Arts, Science & D.D Shirol Commerce College and submitted his inspection report on 17/06/2025 to this office. Based on his inspection report, hereby issuing the renewal of Compliance report to the K.L.E. Society's Shri Channagirishwar Prasadik Arts, Science & D.D Shirol Commerce College, Sy.No.66, 67, 68, 69, Mahalingpur, Rabakavi-Banahatti Taluk, Bagalkot District for compliance of installation of fire fighting system. This renewal of compliance certificate is issued for a period of two year from the date of issue.

Yours Faithfully,



CHIEF FIRE OFFICER

Karnataka State Fire and
Emergency Services, Hubballi Zone
HUBBALLI-25.

To,
The Principal,
Shri C.P.Arts, Science &
D.D.Shirol Commerce College,
Mahalingpur, Bagalkot District

Copy to :

1. The DGP & DG, KSF&ES, Bengaluru for your kind information sir.
2. The District Fire Officer, Bagalkot.

C.No : 417/DFO/CC/Bagalkot/2025.

Office of the District Fire Officer
Karnataka State Fire Service
Fire Station
BAGALKOT-587 102
15/06/2025
Date:

To,

The Chief Fire Officer,
Karnataka State Fire & Emergency Services,
Hubballi, Zone. Hubballi.

Respected Sir,

Sub : Renewal of "Fire safety Compliance Certificate" to K.L.E Society's, Shri Channagirishwar Prasadik Arts, Science & D.D Shirol Commerce College, Sy No : 66, 67, 68, 69, Mahalingpur, Tq-Rabkavi-Banahatti, Dist : Bagalkot.

Ref : 1) C.No : /CFO/Hubballi/2025. Date : 29/05/2025.
2) C.No: 177/ADV/CFO/HBL/2023. Date : 15/03/2023.
3) C.No : 256/CC/DFO/BAGALKOT/2024. Date : 28/03/2024.

With reference to the above subject, I District Fire Officer Bagalkot write to request you that, As per ref (1) The Chief Fire Officer Hubballi Zone, Hubballi, Sir's order The K.L.E Society's, Shri Channagirishwar Prasadik Arts, Science & D.D Shirol Commerce College building consisting of Ground Floor & 01 Upper Floor, situated at Sy No : 66, 67, 68, 69, Mahalingpur, Tq-Rabkavi-Banahatti, Dist : Bagalkot, was inspected by District Fire Officer Bagalkot on 03/06/2025, with respect to Fire Prevention, Fire Fighting and Evacuation measures have been compiled in the above premises with Ref(2) Advice/ recommendations and submitted the details as under.

ANNEXURE-B

(Up to 14.99 mtrs. in height)

"B1 & B2- Schools upto senior secondary level and other institutions"

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)

A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	Principal Shri C.P.Arts, Science & D.D.Shirol Commerce College, Mahalingpur, Bagalkot District.
02	Name and Address of the premises.	:	K.L.E Society's Shri Channagirishwar Prasadik Arts, Science & D.D Shirol Commerce College, Sy No : 66, 67, 68, 69 At : Mahalingpur, Rabkavi-Banahatti Taluk , Bagalkot District
03	Name and address of the Building owner	:	The Chairman K.L.E Society, Belagavi, Dist Belagavi.
04	Number of buildings	:	01 Building

1

PRINCIPAL
K.L.E.Society's
S.C.P.Arts & D.D.S.Commerce College
Mahalingpur 587112 Dist.Bagalkot


05	Number of floors	:	Ground+01 upper floors
06	Floor-wise details of occupancy:-		
	Ground Floor	:	Class Rooms-13, Staff Room-03, Library, Science Room, Office, Assembly Hall.
	First Floor	:	Class Rooms-13, Staff Room-03, Drawing Room, Science Room, Assembly Hall.
07	Height of the building	:	09.60 mtrs
08	Site area	:	04A 25 G
09	Built-up area of each floor:-		
	Ground Floor	:	1868.50 Sq. Mtrs.
	First Floor	:	1868.50 Sq. Mtrs.
10.	Total built-up area	:	3737.00 Sq. Mtrs.
11.	Surrounding properties:-		
	East	:	Vidyanagar
	West	:	Road (Towards Dhawaleshwar) 6 mtr wide
	North	:	Road (Mudhol to Bagalkot) 12 mtr wide
	South	:	Mahantesh Nagar
12.	Set-back area available around the building :-		
	East	:	00.00 Mtrs.
	West	:	03.00 Mtrs.
	North	:	20.00 Mtrs
	South	:	03.00 Mtrs.
	Allowed setbacks (open space) should be maintained free from further obstruction / construction		

Note : Recommended to provide and maintain setbacks as per Local ZR.

- B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :

Sl. No. (1)	Details (02)	Existing (03)			Recommendations (04)
01.	Accessibility to the premises	The premise is abutting by 12.00 mtrs. Wide hard surfaced road located on Northern side.			Adequate
02.	No. of entrances	01 No entrance/ exit of 06.00 mtrs wide is provided for premises.			Adequate
03.	No. of staircases available	Nos. of staircases	:	02	Compiled.
		Width of staircases	:	1.50 mt	
		Width of treads	:	30 cm	
		Height of risers	:	15 cm	
		Nos. of riser per flight	:	9 no.	
		Height of handrails	:	0.90 mt	

04.	Portable Fire extinguishers	<p>Provided as below</p> <p>A. One water mist extinguisher of 9 ltrs capacity are kept near each staircase landing.</p> <p>B. One mechanical foam extinguisher of 9 ltrs. capacity & One ABC type extinguisher of 6 kgs. capacity are kept near diesel generator.</p> <p>C. One CO2 type fire extinguisher, of 4.5 kgs. Capacity are provided near each electrical panel board & electrical room.</p> <p>D. One ABC type fire extinguisher of 06 kgs capacity are installed within 15 mtrs. Radius.</p>	Compiled with adequate no of Fire Extinguishers.
05.	Hose reel hose system	Provided One Hose Reel Hose near the staircase for every 1000 Sq. Mt. The hose reel hose has been connected at each landing of each block.	Compiled
06.	Pump at the terrace tank level with minimum pressure of 3.5 kg/cm ² .	The system has been connected to a booster pump of 450 LPM capacity.	Compiled with adequate capacity of Booster pump.
07.	Diesel Generator	A Diesel generator of 25 KVA capacities has been provided to supply alternative power supply.	Compiled with adequate capacity.
08.	Terrace tank over respective tower terrace.	Provided with 10,000 ltrs of terrace tank.	Compiled.
09.	Escape routes	Provided the Direction in which the employees/ Students should have to move in the event of any emergency have been marked with luminous paint at each floor directing the employees towards emergency exits	Compiled.
10.	Fire order (Fire safety plans)	Fire safety plans indicating with details of actions to be taken in case of an emergency near staircase landings at each floor with telephone numbers of <i>Rabkavi-Banahatti fire station i.e. 08354-2308353-232101 & 101,112</i> telephone numbers of the nearest Ambulance service & Police Station. has been displayed.	Compiled.



 PRINCIPAL
 K.L.E.Society's
 S.C.P.Arts & D.D.S.Commerce College
 Mahalingpur 587312 Dist.Bagalkot

11.	Fire fighting training	Shri Darmendra Aneppagol Shri Prakash Kanti are the 02 trained persons.	Compiled
12.	<u>Fire precautionary measures:-</u> A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. B. Accumulation of combustibile waste in and around the premises should be avoided. C. The exit ways shall be always kept clear without any obstruction. D. Liquefied petroleum gas should not be stored in the building. E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction. F. During the class hours the class room doors shall not be locked from inside to outside. G. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14 th of every year by conducting Fire Safety drills with co-ordinate with fire service department.		

The applicant have compiled all the recommendations mentioned in the ref (2) certificate, Hence herewith recommended to Renew Fire Safety Compliance Certificate of K.L.E Society's, Shri Channagirishwar Prasadik Arts, Science & D.D Shirol Commerce College, Sy No : 66, 67, 68, 69, Mahalingpur, Tq-Rabkavi-Banahatti, Dist : Bagalkot

Submitted for your kind perusal and necessary action sir.

Your's faithfully

 13/06/2024
District Fire Officer
Fire Station
BAGALKOT-587 107



ಚಲನ್ ಚಾಲ್ತಿ ಅವಧಿ Challan Validity	ಜಿಲ್ಲೆ District	ಇಲಾಖೆ Department	ಡಿಡಿಓ ಕಛೇರಿ DDO Office	
7 Days	DHARWAD	DEPARTMENT OF KARNATAKA FIRE & EMERGENCY SERVICES	DIVISIONAL FIRE OFFICE, KARNATAKA FIRE EMERGENCY SERVICES, HUBLI ZONE, HUBLI	
ವರ್ಗ Category	ದಿನಾಂಕ Date	ಚಲನ್ ಉಲ್ಲೇಖ ಸಂಖ್ಯೆ Challan Reference Number	ಡಿಡಿಓ ಕೋಡ್ DDO Code	
Government	17/06/2025 15:01:51	CR0625007000255546	140310	
ಸಂದಾಯದಾರನ ಹೆಸರು Remitter Name		KLESocietySShriChannagirishwarPrasadikArtsScienceD DShirolCommerceCollegeMahalingapur RabakaviBanahattiTalukBagalkotDistrict	ಮೊಬೈಲ್ ಸಂಖ್ಯೆ Mobile Number	8904601004
ವಿಳಾಸ Address	K.L.E. Societys Shri Channagirshwar Prasadik Arts, Science And D.d. Shirol Commerce College, Mahalingapur, Rabakavi Banahatti Taluk, Bagalkot District			
ಉದ್ದೇಶ Purpose	ಲೆಕ್ಕ ಶೀರ್ಷಿಕೆ Head of Account	ಉಪ ಉದ್ದೇಶದ ಹೆಸರು Sub Purpose Name	ಉದ್ದೇಶ ನಿರ್ದಿಷ್ಟ ಐಡಿ Purpose Specific ID	ಮೊತ್ತ Amount
COLLECTION OF FEES AND OTHER RECEIPTS FROM FIRE DEPARTMENT	0070~60~109~0~02~000	RENEWAL CLEARANCE CERTIFICATE	Docket No. : 417/DFO/CCR/BKT/25	1000.00
ಸಂದಾಯ ಮಾಡುವ ಬ್ಯಾಂಕ್ Remittance Bank	State Bank of India e Pay	ಒಟ್ಟು ಮೊತ್ತ Grand Total	1000.00	
		ಒಟ್ಟು ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ Total Amount in Words	One Thousand Only	
ಪಾವತಿ ವಿವರಗಳು\Payment Details				
ಪಾವತಿ ವಿಧ Payment Mode		Debit Card/Credit Card		

*ನಿಮ್ಮ ವಹಿವಾಟನ್ನು ಸಂಸ್ಕರಿಸಲಾಗಿದೆ. ಮುಂದಿನ ಉಲ್ಲೇಖಕ್ಕಾಗಿ ದಯವಿಟ್ಟು ವಹಿವಾಟಿನ ಸಂಖ್ಯೆಯನ್ನು ಬರೆದಿಟ್ಟುಕೊಳ್ಳಿ. ವಹಿವಾಟು ಸಂಖ್ಯೆ

Your Transaction has been processed. Please note the Transaction number for future reference. Transaction No. 7687169113817

*ಕ್ರೆಡಿಟ್ ಕಾರ್ಡ್/ಡೆಬಿಟ್ ಕಾರ್ಡ್ ಮೂಲಕ ಮಾಡಿರುವ ಎಲ್ಲಾ ಪಾವತಿಗಳ ಮೇಲೆ ಹೆಚ್ಚುವರಿ ಸೇವಾ ಶುಲ್ಕ ಅನ್ವಯವಾಗುತ್ತದೆ. ಹಾಗೂ ಬ್ಯಾಂಕ್ ಅದನ್ನು ನೇರವಾಗಿ ಖರ್ಚು ಹಾಕುತ್ತದೆ.

Additional Service charges are applicable for all payments made through CC/DC and the same would be debited directly by the bank.

*ಯಾವುದೇ ಸಂದರ್ಭದಲ್ಲಿ ಸಂದಾಯದಾರನು ಶುಲ್ಕ ಮರುಪಾವತಿಯನ್ನು ಕೊರಬಾರದು

Under no circumstances the remitter will seek a Charge Back